

**SCHEDULE OF QUANTITY FOR AIR CONDITIONING WORK AT PROPOSED
COMMON ROOM**

(1) LAST DATE FOR SUBMISSION OF BID 06/11/24 upto 2.00 P.M.

(2) DATE AND TIME OF OPENING OF BID IN

PRESENCE OF BIDDERS/ REPRESENTATIVES OF BIDDER: -

06/11/24 AT 2.30 P.M.

(3) EARNEST MONRY: Rs.5,000/-

NAME OF FIRM:-

ADDRESS OF FIRM:-

MOBILE NO.

EMAIL ID:-

GST NO

PAN NO

S.No	Item	Unit	Qty	Price per unit	Total Amount
1	Supply , Installation, Testing and Commissioning of Air Cooled SPLIT type Air conditioners complete with Indoor unit(IDU), Out door unit (ODU), R-32/R410A Green Refrigerant, wireless Remote, suitable for 400/230V, +/- 10% 50 Hz ,1 /3 phase AC supply, apable of performing cooling, dehumidification, Air circulation, filtration & ventilation of following capacity with Scroll /rotary/twin rotary compressor. All as per pre approved by Engineer in charge.				
	Non Inverter				
	1.5 Tr Make:- Bluestar/Daikin/Carrier/Hitachi	Each	06		
2	Providing & Fixing of IS : 4985 - 2000 Class -4 (10 Kgf / Sqcm) UPVC drain water piping with fittings (IS:7834 & 10Kgf/sqcm) like elbow, socket, Tee, solvent cement jointing, support with MS hanger on ceiling or recessed in wall with chasing & plastering with 6 mm thick closed cell elastomeric nitrile rubber insulation including leakage testing etc. as required of following Nominal sizes. All as per pre approved by Engineer in charge. For additional technical parameters of products/ work , refer Annexure "A" attached with this BSR .				
	20 mm	Mtr	80		

3	Making hole in stone masonry/ RCC wall/ RCC slab with core cutter for accommodating refrigerant pipe/ drain pipe/ MS pipe/ cables etc of following dia				
	50 mm to 100 mm Dia	Each	06		
4	Supply & fixing MS powder coated stand suitable for 2.5/3.0/4.0 Tr outdoor type of Split/Ductable/Tower AC. All as per pre approved by Engineer in charge. For additional technical parameters of products/ work , refer Annexure "A" attached with this BSR .	Each	06		
5	Supplying and drawing FR PVC insulated & unsheathed flexible copper conductor as per PWD specification for electrical Works with ISI marked(IS:694)and as per IS8130:2013 of 1.1kV grade. Wire should be made from 99.90% purity copper, class 5 stranding inacc. to IS:8130/IEC60228 for lower wattloss, oxygen free or less chances of oxidization, insulation PVC type A/C/D , flame retardant as per IS 10810-53, better amperage rating as per IS:3961 part 5, in existing surface or recessed PVC/ MS conduit/casing capping making connections with Copper Lugs of suitable size, Ferrules, testing etc. as required.				
	2 x 4.0 sq. mm. + 1 x 1.5 sqmm	Mtr	60		
6	Supplying and fixing of power plug point Modular accessories on hot dipped galvanized modular box of 20 SWG on surface or in recessed with suitable size of grid plate with cover plate including cost of modular 16 amp. Switch and socket outlet , making connection , testing , etc. as required.	P. Point	06		

Terms and conditions:-

(1) Payment will be made after satisfactory completion of work/supply of all items.

(2) Required to execute the work/supply the complete items within **30 days** from issue of work order.

(3) The Contractor/firm will adopt all safety measures /precautions while executing the work/supply. In case of any accident /causality of any personnel, involved in work/supply the complete responsibility will be borne by the contractor/firm himself and University will not be held responsible for any claim/compensation.

(4) Successful bidder will be calculated on overall basis of items

SEAL & SIGNATURE OF BIDDER